

Certificate



Intertek

for European Product Safety

Reference No. 1309486

Roof type Fan

Type designation

TFS*****

Certificate holder

Systemair AB
Industrivägen 3
739 30 Skinnskatteberg
SWEDEN

The product complies with
the standard(s)

EN 60335-1:2012
EN 60335-2-80:2003+A1+A2
EN 62233:2008

Date of expiry

4 September 2019

EU-direktivsinformation

Produkten uppfyller kraven för CE-märkning enligt lågspänningsdirektivet
2006/95/EG.

Additional information in Appendix.


Certification Body

Intertek Semko AB, Product Certification

Place

Kista - Stockholm

Signed


Niclas Lood

Date

4 September 2014

Page 1 of 3



Intertek
Appendix

Reference No. 1309486

Technical data

Type designation	TFSR 125 M, TFSK 125 M
Rated voltage (V)	230
Rated power (W)	25
Frequency (Hz)	50
Class	I
IP-Class	44
Type designation	TFSR 125 XL, TFSK 125 XL
Rated voltage (V)	230
Rated power (W)	53
Frequency (Hz)	50
Class	I
IP-Class	44
Type designation	TFSR 160, TFSK 160
Rated voltage (V)	230
Rated power (W)	60
Frequency (Hz)	50
Class	I
IP-Class	44
Type designation	TFSR 200, TFSK 200
Rated voltage (V)	230
Rated power (W)	108
Frequency (Hz)	50
Class	I
IP-Class	44

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Chh



Intertek
Appendix

Reference No. 1309486

Type designation	TFSR 315 M, TFSK 315 M
Rated voltage (V)	230
Rated power (W)	211
Frequency (Hz)	50
Class	I
IP-Class	44

Type designation	TFSR 315 L, TFSK 315 L
Rated voltage (V)	230
Rated power (W)	308
Frequency (Hz)	50
Class	I
IP-Class	44

Manufacturing site(s)	Systemair AB Industrivägen 3 739 30 Skinnskatteberg SWEDEN
-----------------------	---

Certification Body	Intertek Semko AB, Product Certification	Place	Kista - Stockholm
--------------------	--	-------	-------------------

Signed	 Niels Lood	Date	4 September 2014
--------	---	------	------------------

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.